

11/11/2019

Subject: **Scotten Elementary School Modernization**
Grass Valley School District
Project No. 2018045

DSA File No. 29-11
DSA Application No. 02-117268

ADDENDUM NO. #3
(2 Pages Faxed / Emailed Including Attachments)

CHANGES AND/OR CLARIFICATION'S OF THE DRAWINGS AND SPECIFICATIONS AS FOLLOWS:

DRAWINGS

None

SPECIFICATIONS

ITEM NO. 1.1: SPECIFICATION – SECTION: 09 6500-Resilient Flooring

Revise: 2.01 SHEET FLOORING as follows

2.01 SHEET FLOORING

- A. Provide Homogeneous Sheet Vinyl Flooring: ColorArt™ Medintone™ with Diamond 10® Coating manufactured by Armstrong Flooring Inc.
1. Description: An unbacked, nonlayered, homogeneous sheet vinyl flooring. Protected by a diamond-infused UV-cured polyurethane finish, the colors and pattern detail are dispersed uniformly throughout the thickness of the product. Color pigments are insoluble in water and resistant to cleaning agents and light.
 2. Homogeneous sheet flooring shall conform to the requirements of ASTM F1913 Standard Specification for Vinyl Sheet Floor Covering Without Backing
 3. Pattern and Color: in color selected from the range currently available from Armstrong Flooring Inc.
 4. Width: 6 ft. 7 in. (2.0 m).
 5. Length: up to 65.6 lineal feet (20 meters)
 6. Thickness: 0.080 in. (2.0 mm)
- B. Vinyl Weld Rod:
1. Provide solid color vinyl weld rod as produced by Armstrong Flooring Inc., and intended for heat welding of seams. Color shall be compatible with field color of flooring or as selected by Architect to contrast with field color of flooring. Color selected from the range currently available from Armstrong Flooring Inc.
- C. Integral Flash Cove Base:
1. Provide integral flash cove wall base by extending sheet flooring 6 in. (15.24 cm) up the wall using adhesive, welding rod, and accessories recommended and approved by the flooring manufacturer.
- D. Adhesive:
1. For Spray Adhesive High-Moisture Installation Warranty, Full Spread: Provide Armstrong Flooring Flip™ Spray Adhesive for field areas and Armstrong S-580 Flash Cove Adhesive at flash coving as recommended by the flooring manufacturer.

Revise: 2.03 RUBBER FLOORING as follows

2.03 RUBBER FLOORING

- A. Rubber sports flooring: TRUERUBBER® rubber sheet flooring, True Hues, with patented color brightener technology.
1. Manufacturers:
 - a. Mohawk Group, 160 South industrial BLVD., Calhoun, GA 30701
 - b. Substitutions: See Section 01 6000 - PRODUCTS AND SUBSTITUTIONS.
 2. Minimum Requirements: Comply with ASTM F1859 Type-1.
 3. Thickness: 3mm nominal.
 4. Dimensions: 60 inches x 50 feet.
 5. Seams: Heat welded.
 6. Integral coved base with cap strip.
 7. Color: To be selected by Architect from manufacturer's full range.
 8. Game striping and/or accent colors to be selected by Architect from manufacturer's full range. 3 colors minimum.

Revise: 2.02 TILE FLOORING as follows

2.02 TILE FLOORING

- A. LVT click Tile
1. Manufacturers:
 - a. Metroflor: Engage Genesis FX3 Droplock 100
 2. Pattern: 2000MW Multi-width planks, 2054DL Ipswich.

BIDDER QUESTIONS

- Question: I am looking for floor finish confirmation on the following rooms: N9, N8, N4, N5 N13, N14, L10, L11, L12, L13
- Answer: Rooms L6, L7, L8, L9, L10, L11, L12, and L13 all have existing concrete floors and have no work called out and are to be existing to remain. Rooms N4, N5, N8, N9, N13, and N14 all have no work called out and are to be existing to remain.
- Question: Fremont Millwork Co. is planning on bidding all new casework/countertops in lieu of refurbishing of existing. All demo of existing would be by others. Please let me know if that will be acceptable. Otherwise, we will have to pass on this project.
- Answer: Replacement of existing casework that is noted to be refinished will be considered equal to refinishing. Casework is to be to the same specifications as other new casework specified.
- Question: Per spec section 102800 there is no grab bar model number being show. Do we have a model number for this unit as they are shown as new on the plans?
- Answer: B-5806 series. Lengths as noted on plans.
- Question: On A3.52 Det #5 and Det #7 east wall is showing a paper towel dispenser. On Det #5 the floor plan it is keynote#8, and on the elevation it is keynote #14. Which unit is this to be. If it is to be keynote #14 there is also no model number for this style of unit in the spec, and a model number will be needed for bidding. Also we have a similar issue at rooms L6 and L8.
- Answer: Use keynote #14. Bobrick - 813061 or equal.